

ACTIONclima®



 **TR11**

TERMOSTATO
ELETTRONICO

Uscita 0..10V

ELECTRONIC
THERMOSTAT

0..10V Voltage Output

TM-TR11-61022121-R00

MANUALE TECNICO, INSTALLAZIONE, USO USE, INSTALLATION, TECHNICAL MANUAL



CE

REGOLATORE PROPORZIONALE - INTEGRALE

- Regolazione PI
- Uscita 0 .. 10 Volt
- Alimentazione 24V~/=
- Possibilità di regolazione in riduzione notturna
- Possibilità di selezionare il tempo di integrazione
- Banda proporzionale regolabile
- Sonda esterna opzionale

PROPORTIONAL - INTEGRAL REGULATOR

- PI regulation
- 0 .. 10V voltage output
- 24V~/= power supply
- Night reduction facility
- Selectable integration time
- Adjustable proportional band
- Optional external temperature probe

REGULADOR PROPORCIONAL INTEGRAL

- Regulación PI
- 0 .. 10V de salida
- Alimentación 24V~/=
- Posibilidad de reducción nocturna
- Tiempo de integración que se puede seleccionar
- Banda proporcional regulable
- Sonda para la temp. externa opcional






Fig. 1: Aspetto esteriore / External aspect / Aspecto exterior

Selezione del tempo di integrazione
A: 9 min. (regolazione in fabbrica)
B: 18 min.
C: 27 min.
D: 36 min.

Integration time selection
A: 9 min. (factory set)
B: 18 min.
C: 27 min.
D: 36 min.

Selección tiempo de integración
A: 9 min. (regulado en fábrica)
B: 18 min.
C: 27 min.
D: 36 min.




Trimmer banda proporzionale
Proportional band trimmer
Banda trimmer proporcional

Fig. 2: Tempo di integrazione, jumper e trimmer banda proporzionale / Integration time, jumper and proportional band trimmer /
Tiempo de integración, jumper y banda trimmer proporcional

ITALIANO

Funzionamento

Questo dispositivo regola la temperatura ambiente in modo proporzionale-integrale. La tensione di uscita 0 .. 10V si ottiene mediante la somma della parte proporzionale e della parte integrale. La parte proporzionale si ottiene come dimostrato nel seguente grafico:




Quando la temperatura ambiente raggiunge il valore del set-point la tensione di uscita è pari a 5V e diminuisce all'aumentare della temperatura. La banda proporzionale è regolabile mediante un trimmer interno da 1°C a 30°C (Fig. 2). La parte integrale è dipendente dal tempo: quando l'errore tra la temperatura e il set point è fisso, raggiunge il valore della parte proporzionale in un intervallo di tempo uguale al tempo di integrazione, il tempo di integrazione si può selezionare regolando il jumper J1 (Fig. 2).

Una riduzione notturna fissa di 4°C si ottiene collegando un interruttore esterno ai terminali 7 e 8 (la riduzione è attiva quando l'interruttore è chiuso). Diversi regolatori possono essere connessi in parallelo allo stesso interruttore di riduzione notturna (per funzionamento centralizzato, ma la polarità dei collegamenti deve essere rigorosamente rispettata).

Una sonda (opzionale) per la temperatura esterna può essere connessa ai terminali 5 e 6, rimuovendo il jumper J2 vicino al sensore di temperatura interna. Quando si usa il sensore di temperatura interno il jumper J2 deve essere inserito.

Schema di collegamento




ATENZIONE

- Per una corretta regolazione della temperatura ambiente si consiglia di installare il termostato lontano da fonti di calore, correnti d'aria o da pareti particolarmente fredde (ponti termici). Se si usa una sonda a distanza la nota va applicata alla sonda e non al termostato.
- Per i collegamenti della sonda usare cavi di sezione minima 1,5 mm² e di lunghezza massima di 25 m. Non passare i cavi della sonda nelle canalette della rete.
- Collegare l'apparecchio alla rete di alimentazione tramite un interruttore onnipolesante conforme alle norme vigenti e con distanza di apertura dei contatti di almeno 3 mm in ciascun polo.
- L'installazione ed il collegamento elettrico del dispositivo devono essere eseguiti da personale qualificato ed in conformità alle leggi vigenti.
- Prima di effettuare qualsiasi collegamento accertarsi che la rete elettrica sia scollegata.



ENGLISH

This device a proportional-integral room temperature regulator. The output voltage (0 .. 10V) is obtained through the sum of a proportional part and an integral part. The proportional part is obtained as shown in the graphic below.



When the temperature equals the set point, the output voltage is 5V and decrease if the temperature is greater. The proportional band is adjustable through an internal trimmer from 1 to 30°C (see figure 2). The integral part is time-dependent: when the error between the temperature and the set point is fixed, it reaches the value of the integral part in a time interval which equals the integration time. The integration time is selectable by setting the jumper J1 (see figure 2). A fixed 4° night reduction is obtained connecting an external switch on terminals 7 and 8 (the reduction is active when the switch is closed). Several regulators can be connected in parallel to the same night reduction external switch (for centralized operation), but the polarity of the wires must mandatorily be respected.

An (optional) external temperature probe can be connected at terminals 5 and 6, by removing the jumper J2 near the internal temperature probe (see figure 2). When using the internal temperature probe, the jumper J2 must be connected. An wiring diagram for the proportional-integral regulator. Terminals 1, 2, 3, 4, 5, 6, 7, 8 are shown. Power input is 24V~/= 50Hz. Terminal 1 is connected to ground. Terminals 2 and 3 are connected in parallel. Terminals 4 and 5 are connected in parallel. Terminals 6 and 7 are connected in parallel. Terminals 8 and 9 are connected in parallel. Terminals 10 and 11 are connected in parallel. Terminals 12 and 13 are connected in parallel. Terminals 14 and 15 are connected in parallel. Terminals 16 and 17 are connected in parallel. Terminals 18 and 19 are connected in parallel. Terminals 20 and 21 are connected in parallel. Terminals 22 and 23 are connected in parallel. Terminals 24 and 25 are connected in parallel. Terminals 26 and 27 are connected in parallel. Terminals 28 and 29 are connected in parallel. Terminals 30 and 31 are connected in parallel. Terminals 32 and 33 are connected in parallel. Terminals 34 and 35 are connected in parallel. Terminals 36 and 37 are connected in parallel. Terminals 38 and 39 are connected in parallel. Terminals 40 and 41 are connected in parallel. Terminals 42 and 43 are connected in parallel. Terminals 44 and 45 are connected in parallel. Terminals 46 and 47 are connected in parallel. Terminals 48 and 49 are connected in parallel. Terminals 50 and 51 are connected in parallel. Terminals 52 and 53 are connected in parallel. Terminals 54 and 55 are connected in parallel. Terminals 56 and 57 are connected in parallel. Terminals 58 and 59 are connected in parallel. Terminals 60 and 61 are connected in parallel. Terminals 62 and 63 are connected in parallel. Terminals 64 and 65 are connected in parallel. Terminals 66 and 67 are connected in parallel. Terminals 68 and 69 are connected in parallel. Terminals 70 and 71 are connected in parallel. Terminals 72 and 73 are connected in parallel. Terminals 74 and 75 are connected in parallel. Terminals 76 and 77 are connected in parallel. Terminals 78 and 79 are connected in parallel. Terminals 80 and 81 are connected in parallel. Terminals 82 and 83 are connected in parallel. Terminals 84 and 85 are connected in parallel. Terminals 86 and 87 are connected in parallel. Terminals 88 and 89 are connected in parallel. Terminals 90 and 91 are connected in parallel. Terminals 92 and 93 are connected in parallel. Terminals 94 and 95 are connected in parallel. Terminals 96 and 97 are connected in parallel. Terminals 98 and 99 are connected in parallel. Terminals 100 and 101 are connected in parallel. Terminals 102 and 103 are connected in parallel. Terminals 104 and 105 are connected in parallel. Terminals 106 and 107 are connected in parallel. Terminals 108 and 109 are connected in parallel. Terminals 110 and 111 are connected in parallel. Terminals 112 and 113 are connected in parallel. Terminals 114 and 115 are connected in parallel. Terminals 116 and 117 are connected in parallel. Terminals 118 and 119 are connected in parallel. Terminals 120 and 121 are connected in parallel. Terminals 122 and 123 are connected in parallel. Terminals 124 and 125 are connected in parallel. Terminals 126 and 127 are connected in parallel. Terminals 128 and 129 are connected in parallel. Terminals 130 and 131 are connected in parallel. Terminals 132 and 133 are connected in parallel. Terminals 134 and 135 are connected in parallel. Terminals 136 and 137 are connected in parallel. Terminals 138 and 139 are connected in parallel. Terminals 140 and 141 are connected in parallel. Terminals 142 and 143 are connected in parallel. Terminals 144 and 145 are connected in parallel. Terminals 146 and 147 are connected in parallel. Terminals 148 and 149 are connected in parallel. Terminals 150 and 151 are connected in parallel. Terminals 152 and 153 are connected in parallel. Terminals 154 and 155 are connected in parallel. Terminals 156 and 157 are connected in parallel. Terminals 158 and 159 are connected in parallel. Terminals 160 and 161 are connected in parallel. Terminals 162 and 163 are connected in parallel. Terminals 164 and 165 are connected in parallel. Terminals 166 and 167 are connected in parallel. Terminals 168 and 169 are connected in parallel. Terminals 170 and 171 are connected in parallel. Terminals 172 and 173 are connected in parallel. Terminals 174 and 175 are connected in parallel. Terminals 176 and 177 are connected in parallel. Terminals 178 and 179 are connected in parallel. Terminals 180 and 181 are connected in parallel. Terminals 182 and 183 are connected in parallel. Terminals 184 and 185 are connected in parallel. Terminals 186 and 187 are connected in parallel. Terminals 188 and 189 are connected in parallel. Terminals 190 and 191 are connected in parallel. Terminals 192 and 193 are connected in parallel. Terminals 194 and 195 are connected in parallel. Terminals 196 and 197 are connected in parallel. Terminals 198 and 199 are connected in parallel. Terminals 200 and 201 are connected in parallel. Terminals 202 and 203 are connected in parallel. Terminals 204 and 205 are connected in parallel. Terminals 206 and 207 are connected in parallel. Terminals 208 and 209 are connected in parallel. Terminals 210 and 211 are connected in parallel. Terminals 212



ACTIONclima®

ACTIONCLIMA S.r.l. - 31030 BIBAN FRAZIONE DI CARBONERA - Via Biban, 54
TREviso (ITALY) - Tel.: (+39) 0422-699923 - Fax.: (+39) 0422-445768
www.actionclima.it - e-mail: info@actionclima.it